



## Non Rigid Fire Barrier

**Certificate number: IFCC 1460**

This is a product certificate to certify that

### ***TBA Protective Technologies Ltd,***

*Unit 3 Transpennine Trading Estate  
Gorrells Way, Rochdale,  
Lancashire OL11 2PX*

Phone: 01706 647422

Who fabricate the following:

### ***Non Rigid Fire Barriers***

Type	Integrity (Mins)	Insulation (Mins)	Orientation
Vulcan Lite	30	15	Vertical
Vulcan Lite	60	15	Horizontal

have successfully completed the requirements of the SDP 21 (Non Rigid Fire Barrier) scheme. This includes the fire testing of products to **BS 476: Part 22: 1987** the inspection of their Factory Production Control and continuing surveillance assessments and testing of samples of products taken from production. The product specification and field of application to achieve the performances as shown in the table above is detailed in the accompanying schedules:



Schedule number: IFCC 1460/S01, S02  
Initial certification: 20 December 2018  
Revised: 11 July 2019  
Valid to: 19 December 2023  
Issue No.: 3



175

Ian Woodhouse  
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.