



## **FIRE RESISTING PARTITION SYSTEM**

***Certificate number: IFCC 1464***

This is a product certificate to certify that

***Domopan Qatar W.L.L.***

*BLDG 73 ST.6  
NEW INDUSTRIAL AREA  
DOHA, QATAR*

Phone: 00974 44099999

Who fabricate the following:

***GYP SUM BLOCK DOMOBLOCK-G REGULAR  
(620MM X 400MM X 150MM & 620MM x 400MM x 200MM)  
&  
FD120 DOMOGYPSUM REGULAR BOARD  
(1000MM x 600MM x 25MM)***

have successfully completed the requirements of the SDP 21 (Partitions) scheme. This includes the fire testing of products to **EN 1364-1** the inspection of their Factory Production Control and continuing surveillance assessments and testing of samples of products taken from production. The product specification and field of application to achieve up to **240 minutes integrity & insulation** is detailed in the accompanying schedule:

Schedule number: IFCC 1464/S01 & IFCC 1464/S02



Initial certification: 02 January 2019  
Revised: 20 March 2020  
Valid to: 01 January 2024  
Issue No.: 3

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.