



NON RIGID FIRE BARRIER

Certificate number: IFCC 1473

This is a product certificate to certify that

TBA Protective Technologies Ltd,

*Unit 3 Transpennine Trading Estate
Gorrells Way, Rochdale,
Lancashire OL11 2PX*

Phone: 01706 647422

Who fabricate the following:

Plus 60 (60/30) Vertical Non Rigid Fire Barrier

have successfully completed the requirements of the SDP 21 (Non Rigid Fire Barrier) scheme. This includes the fire testing of products to **BS 476: Part 22: 1987** the inspection of their Factory Production Control and continuing surveillance assessments and testing of samples of products taken from production. The product specification and field of application to achieve up to **60 minutes integrity & 30 minutes insulation** is detailed in the accompanying schedule:



Schedule number: IFCC 1473/S01
Initial certification: 09 January 2019
Revised: 20 June 2019
Valid to: 08 January 2024
Issue No.: 2



175

A handwritten signature in black ink, which appears to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.