



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1502

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

***Wood and Metal WLL
(A Division of Al Muftah Group)***

Plot No. BA-LP-A-228

Birkat Al Awamer Logistic Park

PO Box 875

Doha - Qatar

Tel: +974 3351 2740

Who fabricate the following timber fire doors and or doorsets:

**Kingsa FD30 Kingsa FD60 Kingsa FD90 Kingsa FD120
Halspan FD30 Halspan FD60 Halspan FD90 Halspan FD120
FireBan FD30 FireBan FD60 FireBan FD90 FireBan FD120**

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: KS01, KS02, KS03, KS04, HS01, HS02, HS04, HS05, HS06, GTL03, GTL04



First Issued: 20 June 2019

Revised 07 June 2022

Valid to: 19 June 2024

Issue No: 3

Ian Woodhouse

Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.