



## **FIRE RESISTANT TIMBER FIRE DOORS**

**Certificate number: IFCC 1604**

*Certificate only valid if verified on website - [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

***Al Habib Al Araimi Trading  
Establishment***

**Sur, Sanoya  
Muscat  
Oman**

Tel. 99 233 235

Who fabricate the following timber fire doors and or doorsets:

**FireBan FD30    FireBan FD60    FireBan FD90    FireBan FD120**

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: GTLS03 & GTLS04



First Issued: 19 October 2020  
Valid to: 18 October 2025  
Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.



**175**

**Ian Woodhouse  
Director of Certification**

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK  
Tel: +44 (0)1844-275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.