



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC1657

Certificate only valid if verified on website www.ifccertification.com

This is a product certificate to certify that

Royde & Tucker T/A Cadwell Green Doors

Unit 6, Bilton Road
Cadwell Lane, Hitchin
Hertfordshire. SG4 0SB

Tel: 01462 44 44 62

Who fabricate the following timber fire doors and or doorsets

Timber Panelled Doorsets FD30, FD30S & FD60, FD60S

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22 and Part 31**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes** integrity are detailed on page 2 of this certificate.

Manufacturing site: A-ZD



First Issued: 06 Aug 2021
Valid to: 05 Aug 2026
Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

Page 1 of 2

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

F27 ©IFC Certification Ltd 2004



Certificate number: IFCC 1657

The production of fire resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Doorset Description	Fire Rating	Assessment/ Test Report
Timber Panelled Doorsets	FD30, FD30S	Chilt/A09136
Timber Panelled Doorsets	FD60, FD60S	Chilt/A09165

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.