



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1665

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

ASLANDAG AHSAP A.S
Tepeören Mah. Atayolu Cad.
No: 5/1 Tuzla
Istanbul / Turkey

Tel. : (+90) 216 4273737

Who fabricate the following timber fire doors and or doorsets:

Sauerland FD30 FD60, Strebord FD30 FD60 FD90
Artella (Own Design) FD60, Ramkor FD120

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: PAR12033/01, PAR13211/01/02/03, PAR13088/01, SS01, SS02, Chilt /RF10026, PAR/19681/01



First Issued: 22 September 2021

Revised: 29 November 2021

Valid to: 21 September 2026

Issue No: 2

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.