



# FIRE RESISTANT METAL BASED DOOR SCHEME

**Certificate number: IFCC 1666**

*Certificate only valid if verified on website - [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

## **Rhino Systems Limited**

Maritime Road,  
Llewellyns Quay,  
Port Talbot  
SA13 1RF  
Tel: 01704 898594

who fabricate the following steel fire doorsets:

### **Own Design E90Sa Rhino Steel Doorsets**

have satisfied the requirements of the SDP02 Fire resistant metal based door scheme. This includes the testing of products to **EN1634-1 and EN1634-3**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production.

The product specifications to achieve up to **90 minutes Fire Resistance (Integrity)** are given in the following test and assessment reports:

20-001996-PR04, 20-005237-PR01 & WYC434190, WF502763 & WF510662



Initial certification: 17 September 2021

Revised: 13 January 2022

Valid to: 16 September 2026

Issue status: 2



175

Ian Woodhouse  
Director of Certification

IFC Certification Ltd  
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.