



FIRE RESISTANT STEEL DOORSETS

Certificate number: IFCC 1704

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Fitzpatrick s.a.l.

Meker Building – Industrial City
Nahr El Mott
Beirut, Lebanon
Tel no: +961 1 901888

Who fabricate the following metal fire doorsets

Steel door SADL with vision panel FD60
Steel door SASL without vision panel FD90
Steel door SADL without vision panel FD180

have satisfied the requirements of the IFCC SDP 02 scheme. This includes the testing of products to **EN 1634-1:2014+A1:2018**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 to 180 minutes integrity** are detailed in the following reports:-

Report No. PAR/22398/01 & PAR/22398/02



First Issued: 08 February 2022

Valid to: 07 February 2027

Issue No: 1

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.