



FIRE RESISTANT METAL BASED DOOR SCHEME

Certificate number: IFCC 1707

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Almuraikhi Est

Street No 47, Building No 1
Industry Area
Doha, Qatar 8027

Tel: +974 5528 2518
Mob: +974 558 14609

who fabricate the following steel fire doorsets:

Own Design FD180 Steel Single & Double Doorsets with Vision Panels & Honeycomb Infil

have satisfied the requirements of the SDP02 Fire resistant metal based door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production.

The product specifications to achieve **from 30 minutes to 180 minutes Fire Resistance (Integrity)** are given in the following test report: VL107-1&2



Initial certification: 21 February 2022

Valid to: 20 February 2027

Issue status: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.