



FIRE RESISTANT METAL BASED DOOR SCHEME

Certificate number: IFCC 1720

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Ascot Doors Ltd

Brittania Way Industrial Park,
Union Rd, Bolton
BL2 2HE

Tel: 01204 545 801

who fabricate the following steel roller shutters:

Own Design EW240 A234-A239 Insulated Roller Shutters

have satisfied the requirements of the SDP02 Fire resistant metal based door scheme. This includes the testing of products to **EN1634-1**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production.

The product specifications to achieve **from 30 minutes to 240 minutes Fire Resistance (Integrity) and Radiation** are given in the following test and EXAP reports: 504486/R & 508984.



Initial certification: 06 April 2022

Valid to: 05 April 2027

Issue status: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire, England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.