



PENETRATION & LINEAR GAP SEALS SCHEME SDP13

Certificate number: IFCC 1726

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Pre-Formed Components Ltd trading as

PFC COROFIL

Units 3 & 4
King George Trading Estate
Davis Road
Surrey
KT9 1TT
Telephone no. +44 (0) 208 391 0533
www.pfc-corofil.com

Which manufacture the following systems:

PFC Corofil Linear Gap Strip (CCFB)

have satisfied the requirements of the above scheme. This includes the testing of products to BSEN 1366-4: 2021, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications to achieve up to 120 minutes Fire Resistance (Integrity) are given in the following report detailed below:

Test Report: WF510661/R

First Issued: 31 May 2022

Valid to: 30 May 2027

Issue status: 1



175

A handwritten signature in black ink, which appears to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.