



PENETRATION & LINEAR GAP SEALS SCHEME SDP13

Certificate number: IFCC 1728

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

ARC Building Solutions Ltd

Unit J Gildersome Spur

Leeds

West Yorkshire

LS27 7JZ

Telephone no. : 0113 252 9428

Which manufacture the following systems:

ARC Party Wall DPC & T-Barrier

have satisfied the requirements of the above scheme. This includes the testing of products to EN1366-4 the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and reports are detailed on page 2 of this certificate.



First Issued: 27 July 2022

Valid to: 26 July 2027

Issue status: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

Page 1 of 2

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

IFCC 1728

ARC Party Wall Cavity Stop Sock & Party Wall DPC

Cavity Size (mm)	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Thickness (mm)	Orientation	Test (Specimen)
0-300	M	240/120	None	250	H	WF 513959 (A)
0-300	M	240/120	None	250	V	WF 358532 (E)

ARC Party Wall TCB

Cavity Size (mm)	Substrate Type	Rating E/I (mins)	Compression Fit (mm)	Thickness (mm)	Orientation	Test (Specimen)
0-150	01/M	60/60	5	250	V H	WF 438534B (D) WF 517911 (B)

ARC T-Barrier (Masonry)

<u>Cavity Size (mm)</u>	<u>Substrate Type</u>	<u>Rating E/I (mins)</u>	<u>Compression Fit (mm)</u>	<u>Thickness (mm)</u>	<u>Orientation</u>	<u>Test (Specimen)</u>
<u>0-300</u>	<u>M</u>	<u>240/120</u>	<u>None</u>	<u>250</u>	H	WF 513959 (A)
<u>0-300</u>	<u>M</u>	<u>240/120</u>	<u>None</u>	<u>250</u>	V	WF 358532 (E)

ARC T-Barrier (Timber Frame)

<u>Cavity Size (mm)</u>	<u>Substrate Type</u>	<u>Rating E/I (mins)</u>	<u>Compression Fit (mm)</u>	<u>Thickness (mm)</u>	<u>Orientation</u>	<u>Test (Specimen)</u>
<u>0-150</u>	<u>01/M</u>	<u>60/60</u>	<u>5</u>	<u>250</u>	V	WF 438534B (D)

M = Masonry, H = Horizontal, V = Vertical, 01/M = OSB 1 side &/or masonry, 02/M = OSB 2 side &/or masonry