



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1738

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Al Qasr Al Mukhmali Manufacturing

4202 Aldilam

Alolaiya District

Riyadh

Kingdom of Saudi Arabia

Tel. (966) 112155 550

Who fabricate the following timber fire doors and or doorsets:

Halspan FD30

Halspan FD60

Halspan FD90

Halspan FD120

FireBan FD30

FireBan FD60

FireBan FD90

FireBan FD120

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule refs: HS01 - HS06, GTLS03, GTLS04



First Issued: 21 June 2022

Valid to: 20 June 2027

Issue No:1



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.