



Metal Fire Doors

Certificate number: IFCC1739

This is a product certificate to certify that

Beauty Design Company

Istanboul Street

Riyadh

Saudi Arabia

Tel. 00966 1 265 6555

Who fabricate the following fire rated Steel Fire Doors:

LSADL FD120 Steel Doorset with honeycomb infill and vision panel

LSASL FD120 Steel Doorset with honeycomb infill and vision panel

LSADL FD180 Steel Doorset with mineral wool infill

have satisfied the requirements of the SDP02 Metal Fire Doors scheme. This includes the testing of products to **UL10C**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **120 minutes to 180 minutes integrity** are detailed in the reports referenced below.

Test reports: WC101-2 (LSADL FD180) WC101-3&4 (A – LSADL FD120, B - LSASL FD120)



First Issued: 28 June 2022

Valid to: 27 June 2027

Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, Ground Floor Suite B Building 2. Bear Brook Office Park, Walton Street. Aylesbury HP21 7GQ UK
Tel: +44 (0)1844 276920 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.