



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1742
(Formerly FRTD556)

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Al Khaleej Modern Light Carpentry

Street 46, Gate No 68

Industrial Area

Doha

Qatar

Tel. 00974 55669847/00974 55308556/00974 55897380

Who fabricate the following timber fire doors and or doorsets:

Halspan FD30	Halspan FD60	Halspan FD90	Halspan FD120
FireBan FD30	FireBan FD60	FireBan FD90	FireBan FD120

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule refs: HS01 - HS06, GTLS03, GTLS04



First Issued: 30 June 2022

Valid to: 29 June 2027

Issue No: 1

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, Ground Floor, Suite A, Building 2, Bear Brook Office Park, Walton St, Aylesbury, HP21 7GQ, UK
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.