



# FIRE RESISTANT TIMBER FIRE DOORS

**Certificate number: IFCC1746**

*Certificate only valid if verified on website [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

***Punto Interiors Ltd Co.,***

Mutlukent MAH 2024

CAD No.43

Cankaya/Ankara

Turkey

Tel: (+90312) 441 45 70

Who fabricate the following timber fire doors and or doorsets:

**SASL with Steel Frame EI 45**

**SADL with Steel Frame EI 45**

**SASL with Steel Frame + Vision Panel E 45**

have satisfied the requirements of the SDP01 Fire Resistant Timber Door scheme. This includes the testing of products to **EN1634-1** the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve upto **45 minutes integrity & insulation** are detailed in the test reports referenced below.

Test report refs: TSE6964/02-22, TSE6994/02-22 & TSE7003/02-22



First Issued: 05 August 2022

Valid to: 04 August 2027

Issue No: 1

Ian Woodhouse

Director of Certification



175

IFC Certification Ltd, Ground Floor, Suite B, Building 2, Bear Brook Office Park, Walton Street, Aylesbury HP21 7GQ

Tel: +44(0) 1844 275500, Fax: +44(0) 1844 274002, E-mail: [uk.ifccinfo@kiwa.com](mailto:uk.ifccinfo@kiwa.com)

Web: [www.ifccertification.com](http://www.ifccertification.com) Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd 2022