



FIRE RESISTANT METAL BASED DOOR SCHEME

Certificate number: IFCC 1747

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Rhino Systems Limited

Maritime Road,
Llewellyns Quay,
Port Talbot
SA13 1RF

Tel: 01704 898594

who fabricate the following steel fire doorsets:

Own Design E60 Single & Double Hinged Personnel Doors (Rhino-HCFD-60)

have satisfied the requirements of the SDP02 Fire resistant metal based door scheme. This includes the testing of products to **EN1634-1**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production.

The product specifications to achieve up to **60 minutes Fire Resistance (Integrity)** are given in the following test reports: WF502479/R (Single) & WF509258/R (Double)



Initial certification: 05 August 2022

Valid to: 04 August 2027

Issue status: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.