



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1765

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Hala Industrial Company for Prefabricated Houses

**P.O. Box 2270, Safat 13023, Block-10,
Street-5, Sabhan Industrial Area**

Kuwait

&

**P.O Box 42023, Shuwaikh 70651,
Kuwait**

Tel. +965-24834922

Who fabricate the following timber fire doors and or doorsets:

Halspan FD30	Halspan FD60	Halspan FD90	Halspan FD120
FireBan FD30	FireBan FD60	FireBan FD90	FireBan FD120

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule refs: HS01 - HS06, GTLS03, GTLS04



First Issued: 16 November 2022

Valid to: 15 November 2027

Issue No: 1

Ian Woodhouse

Director of Certification



175

IFC Certification Ltd, Ground Floor, Suite A, Building 2, Bear Brook Office Park, Walton St, Aylesbury, HP21 7GQ, UK
Tel: +44 (0)1844 276920 E-mail: uk.ifccinfo@kiwa.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.