



## FIRE RESISTANT TIMBER FIRE DOORS

**Certificate number: IFCC 1581**

*Certificate only valid if verified on website - [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

***Al Wadi Al Kabir Carpentry LLC***

**PO BOX: 445 PC:117**

**Wadi Kabir**

**Sultanate Of Oman**

Tel: 24812856

Who fabricate the following timber fire doors and or doorsets:

**Halspan FD30    Halspan FD60    Halspan FD90    Halspan FD120**

**Strebord FD30    Strebord FD60    Ramkor FD90    Ramkor FD120**

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01 - HS06, SS01, SS02, RA02, RA03



First Issued: 05 August 2020

Valid to: 04 August 2025

Issue No: 1

Ian Woodhouse  
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK  
Tel: +44 (0)1844-275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.