



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC1297

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Maroudas Stylianos
(Trading as Prisma Door Ltd)

18th KM National Road Thessaloniki - Kavala Kavalari Langadas,
Thessaloniki
Tel: 0030 2394052200

Who fabricate the following timber fire doors and or doorsets:

Halspan FD30

Halspan FD60

Halspan FD90

Halspan FD120

Strebord FD30

Strebord FD60

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes** integrity are detailed in the schedules referenced below.



Schedule ref: HS01-HS06, SS01, SS02

First Issued: 05 May 2017

Reissued: 20 May 2022

Valid to: 04 May 2023

Issue No: 5



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.