



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: FRTD585

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Xylourgion Achillea Panteli Ltd

10 Diorios Street
Nicosia 2540
Cyprus
+ 00357 22488711

Who fabricate the following timber fire doors and or doorsets:

Halspan FD30 Halspan FD90 Halspan FD60
Halspan FD120 Strebord FD30 Strebord FD60

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01, HS02, HS03, HS04, HS05, HS06, SS01, SS02



First Issued: 12 December 2011
Reissued: 06 June 2022
Valid to: 11 December 2022
Issue No: 7



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.