



FIRE RATED DUCTWORK & COMPONENTS SCHEME

Certificate number: FRD600a

This is a product certificate to certify that

Firemac Ltd

11 Abbey Road
North Berwick
East Lothian EH39 4BS
Telephone no. +44 (0) 16 2089 2202

Who manufacture the following product

Firemac FM Fabric for Use in Firemac FM Fire Duct Systems

have satisfied the requirements of the SDP 26-1 Fire Resisting Ducts (including Smoke Extraction) & Components scheme. This includes the testing of products to **BS476: Part 24 (ISO 6944: 1985)**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve up to **2 hrs (insulated) and 4 hrs (uninsulated) to BS 476: Part 24** are detailed in the schedules referenced below.



Schedules ref: FRD600/S08, S09, S10,
S11, S12, S13, S14, S15 & S16
First Issued: 20 January 2012
Reissued: 19 January 2021
Revised 01 June 2022
Valid to: 19 January 2026
Issue No: 4



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.