



## **FIRE RESISTANT CEILING SCHEME SDP21**

***Certificate number: IFCC1064***

This is a product certificate to certify that

### ***Firemac FM Blue Ltd***

11 Abbey Road  
North Berwick  
East Lothian EH39 4BS  
Telephone no. +44 (0) 1620 892202

Who supply the following systems

#### **FM Blue Ceiling Membrane Systems**

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22: 1987 (ISO 834: 1985)**. The inspection of their Factory Production Control and continuing surveillance audits including testing of samples of products taken from production. The product specification and field of application to achieve where applicable up to **240 minutes stability, Integrity and up to 120 minutes Insulation** as a ceiling from fire above and below are detailed in the schedule referenced below.



Schedules ref: IFCC1064/S01  
First Issued: 07 January 2014  
Revised: 14 January 2020  
Valid to: 06 January 2024  
Issue No: 2



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse**  
Director of Certification

---

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK.  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.