



FIRE RATED DUCTWORK & COMPONENTS SCHEME

Certificate number: IFCC1410

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Firemac Ltd

11 Abbey Road
North Berwick
East Lothian EH39 4BS
Telephone no. +44 (0) 16 2089 2202

Who manufacture the following product:

Firemac FM Fabric for Use in Firemac FM (EN) Fire Duct Systems

have satisfied the requirements of the SDP 26-2 & SDP 26-3 Fire Resisting Ducts (including smoke extraction) & Components scheme. This includes the testing of products to **EN 1366-1, EN 1366-8 & EN1366-9** the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application will achieve **2 hours integrity and insulation (duct type A) and 2 hours integrity and 1 hours insulation (duct types A and B) to BS EN 1366-1, and 2 hours integrity to BS EN 1366-8 and BS EN 1366-9**, as detailed in the test reports referenced on page 2 of this certificate:



First Issued: 09 August 2018
Re-issued: 02 July 2021
Revised: 07 September 2022
Valid to: 08 August 2023
Issue No: 6



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, Ground Floor, Building 2, Bear Brook Office Park, Walton Street, Aylesbury, HP21 7GQ, UK
Tel: +44 (0)1844 276920 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

Page 1 of 2

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

Certificate number: IFCC 1410

The products are manufactured in accordance with assessment/ test reports referenced within the following table:

Ownership of report	Assessment/ Test Report
Firemac Limited	15/10405-2202
Firemac Limited	14/10405-2423
Firemac Limited	17/13941-112
Firemac Limited	LP01 2758 14 Z00NP
Firemac Limited	17/13492-111-1
Firemac Limited	17/13492-111
Firemac Limited	PGA11712A
Firemac Limited	PGA11485A
Firemac Limited	PGA11488A
Firemac Limited	PGA11489A
Firemac Limited	PGA11489B
Firemac Limited	PGA11713A

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.