



## **FIRE RESISTANT TIMBER FIRE DOORS**

***Certificate number: IFCC 1046***

This is a product certificate to certify that

***Riyan Overseas LLC***

PO Box 884

P. Code 117, Wadi Kabir, Muscat  
Sultanate of Oman

Telephone No. +968 2 481 8355 Fax No. +968 2 481 8142

Email: [firedoors@riyanmuscat.com](mailto:firedoors@riyanmuscat.com), [mail@riyanmuscat.com](mailto:mail@riyanmuscat.com)

Who fabricate the following fire doors:

**Strebord FD30, FD60**

**Ramkor FD 90**

**Kingsa FD30, FD60, FD90, FD120**

**Halspan FD30, FD60, FD90, FD120**

**FireBan FD30, FD60, FD90, FD120**

**Moralt FD30, FD60, FD90**

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30, 60, 90 and 120 minutes integrity** are detailed in the schedules referenced below.



Schedules ref: SS01, SS02, RA01,  
KS01, KS02, KS03, HS01-HS06, MS01

First Issued: 17 October 2013

Re-issued: 17 October 2018

Revised 24 December 2019

Valid to: 16 October 2023

Issue No: 6

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse**  
Director of Certification



**175**

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.