



# FIRE RATED DUCTWORK & COMPONENTS SCHEME

**Certificate number: IFCC1483**

Certificate only valid if verified on website - [www.ifccertification.com](http://www.ifccertification.com)

This is a product certificate to certify that

## **CATDUCT**

(Central Air-Conditioning Trading & Service's Co WLL)  
P.O. Box: 40688,  
Street #10, Building No.172  
AAMCO Premises, New Industrial Area, Doha, Qatar  
Telephone no. (+974) 4451 5756

Who supply the following products

## **CATFIRE Fire Duct Systems**

have satisfied the requirements of the SDP 26-1 fire resisting ducts (including smoke extraction) and components scheme, Appendix A. This includes the testing of products to **BS 476: Part 24: 1987 (ISO 8944: 1985)**. The inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve up to **120 minutes stability and integrity** are detailed in the schedule referenced below.

Schedules ref: IFCC1483/S01, IFCC1483/S02



First Issued: 21 Feb 2019  
Revised: 16 Dec 2021  
Valid to: 20 Feb 2024  
Issue No: 2

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.