



## FIRE RESISTANT TIMBER GLAZED SCREENS

**Certificate number: IFCC1571**

*Certificate only valid if verified on website - [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

***Xylourgika Simos & Lazaros Ltd***

Industrial Area Alampras  
2563 Alampras  
Nicosia

Telephone no. 00357 22 527 224

Who fabricate timber fire resisting elements with the following glasses:

**7mm Pyroguard EW30  
11mm Pyroguard Maxi EW30 & EW60**

have satisfied the requirements of scheme SDP 09. This includes the testing of products to **BS476: Part 22, EN1363-1 or EN 1364-1** as appropriate, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications and fields of application to achieve from **30 mins to 60 mins integrity** are detailed in the schedule referenced below. As this certificate invokes CF257 it cannot remain valid after the expiry date of CF257.

Schedule ref: IFCC1571/S01



Initial certification: 01 July 2020  
Reissued: 06 August 2021  
Valid to: 30 June 2022  
Issue status: 2



175

Ian Woodhouse  
Director of Certification

IFC Certification Ltd  
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.