



FIRE RATED DUCTWORK & COMPONENTS SCHEME

Certificate number: IFCC1599

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Arabian Duct Factory W.L.L

Arabian Duct Factory WLL

B271, St1, Zone 81

New Industrial Area

Doha - Qatar 201756

Telephone no. (+974) 44513536

Who fabricate the following ductwork

Fireflame Ducting Systems

have satisfied the requirements of the SDP 26-1 fire resisting ducts (including smoke extraction) and components scheme, Appendix A. This includes the testing of products to **BS 476: Part 24: 1987**. The inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **up to 120 minutes stability and integrity** are detailed in the schedule referenced below.



Schedules ref: IFCC1599/S01

First Issued: 22 Oct 2020

Valid to: 21 Oct 2025

Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse

Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.