



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1125

Certificate only valid if verified on website –

www.ifccertification.com

This is a product certificate to certify that the

Bahwan Furnishings & Trading LLC

PO Box 169
PC-100 Muscat
Sultanate of Oman

Tel: +968 24446002
Email: bft@suhaibahwangroup.com

Who fabricate the following timber fire doors and or doorsets:

Halspan FD30, FD60, FD90 and FD120

Kingsa FD30, FD60, FD90 and FD120

have satisfied the requirements of IFCC SDP01 Fire resistant Timber Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedule referenced below.

Schedules ref: HS01-HS06, KS01-KS04, Chilt/A05151, FEA/F01205



First Issued: 27 February 2015
Reissued 25 June 2020
Valid to: 26 February 2025
Issue No: 5 -

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.