



# FIRE RESISTANT TIMBER FIRE DOORS

**Certificate number: IFCC1277**

This is a product certificate to certify that

**ANASTASIS GREGORIOU**

**4A Evripidou – Aradippou**

**Larnaca 7104**

**Cyprus**

Tel: 00357-24-533535

Who fabricate the following fire doors:

**Halspan FD30    Halspan FD60    Halspan FD90    Halspan FD120**

**Strebord FD30    Strebord FD60**

have satisfied the requirements of the SDP01 Fire Resistant Timber & Wood Based Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01 - HS06, SS01 & SS02



First Issued: 10<sup>th</sup> Feb 2017

Reissued: 16<sup>th</sup> Feb 2022

Valid to: 9<sup>h</sup> Feb 2023

Issue No: 2



175

Ian Woodhouse  
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.