

FIRE RESISTANT TIMBER FIRE DOORS SDP01

Certificate number: IFCC1278

This is a product certificate to certify that

Galleria Art

Building No 225, Street No 250, Zone No 44 Nuaiji Area PO BOX 32163 Doha, Qatar

(Lusail Factory for Luxury Wooden Furniture)

New Industrial Area Zone 81, Street 07, Building No, 129

Tel: +974 4463 1483 / 4477 1588 / 4477 2669, Mob: +974 5563 5388

Fax: +974 4477 0613, Email: info@galleria-qatar.com

Who fabricate the following fire doors:

Halspan FD30 Halspan FD60 Halspan FD90 Halspan FD120

Fireban FD30 Fireban FD60 Fireban FD90 Fireban FD120

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01-HS06 & GTL S03, GTL S04



First Issued: 30 January 2017 Reissued: 02 February 2022 Revised: 16 February 2022 Valid to: 29 January 2027

Issue No: 2



175

Ian Woodhouse Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.