



## **FIRE RESISTANT STEEL FIRE DOORS**

***Certificate number: IFCC 1423***

This is a product certificate to certify that

***Laussane Metal Industries***

P.O. Box 14666,  
Doha, Qatar (Street 52, Industrial Area)

Tel: 00974-33062469, 00974-66575816  
Email: [info@laussanemetal.com](mailto:info@laussanemetal.com)

Who fabricate the following:

**LMI-FD180, Single & Double Leaf Metal Doorsets with  
Honeycomb Infill & Vision Panels & Bottom Louver**

have satisfied the requirements of the SDP02 Fire Resistant Metal Based Doors scheme. This includes the evaluation of products to **BS476: Part22: 1987**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **30 to 180 minutes integrity** performance are detailed in the schedule referenced below.

Schedule ref: IFCC/1423/S01, IFCC/1423/S02



First Issued: 22/10/2018  
Revised: 03/06/2020  
Valid to: 21/10/2023  
Issue No: 2



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse**  
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.