

CATDUCT

(Central Air-Conditioning Trading & Service's Co WLL)

Product range

CATFIRE 120 Fire Duct System

**2 hrs Fire Resistance of an Insulated Duct Type A and Uninsulated Duct Type B
Ventilation Smoke and Kitchen Extract System. BS476: Part 24:1987 (ISO 6944: 1985)**

Manufacturing locations:

AAMCO Premises, New Industrial Area, Doha - Qatar

**The application of this product should be carried out following the
manufacturers' instructions and according to the following document:**

Assessment Report No.

PAR/21559/01 Rev A

This schedule must be read in conjunction with report PAR/21559/01 Rev A and all aspects of the specification and limitations defined therein must be satisfied. Failure to comply with all specifications will invalidate the approval, and may jeopardise the fire performance.



Director of Certification
Ian Woodhouse

Date: 16 December 2021

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd