



## **FIRE RESISTANT TIMBER FIRE DOORS**

***Certificate number: IFCC1519***

*Certificate only valid if verified on website - [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

***Heze Maosheng Wood Products Co. Ltd.***

Zhuangzhai Town  
Heze City, 274000  
Shandong Province  
China

Tel: 0086-530-6160717

who fabricate the following timber fire doors:

### **Maosheng Board FD30, FD60, FD90, & FD120**

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **FD30, FD60, FD90, and FD120** performance classifications are detailed on page 2 of this certificate.



First Issued: 02 September 2019  
Revised: 21 June 2022  
Valid to: 01 September 2024  
Issue No: 2



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse**  
Director of Certification

---

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +44(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

## ***Certificate number: IFCC 1519***

The production of fire-resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

<b>Doorset Description</b>	<b>Fire Rating</b>	<b>Assessment/ Test Report</b>
Maosheng Board 44mm thick	FD30	PAR19761/01
Maosheng Board 54mm thick	FD60	PAR19761/01
Maosheng Particleboard 64mm thick	FD90	220511997
Maosheng Composite Particleboard 64mm thick	FD120	220511997

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

**It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.**

**Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.**