



Schedule No: IFCC1548/S01 to Certificate no. IFCC1548

DVAC

(Duct Ventilation Air Conditioning Co. (W.L.L))

Product range

DVAC 120 Fire Duct System

2 hrs Fire Resistance of an Uninsulated Duct Type A and Uninsulated Duct Type B
BS476: Part 24:1987

The application of this product should be carried out following the manufacturers' instructions and according to the following documents:

Test Report No.
19/19102-496

Assessment Report No.
19-17654-651 M1

This schedule must be read in conjunction with test report 19/19102-496 and assessment report 19 -17654 -651 M1 all aspects of the specification and limitations defined therein must be satisfied. Failure to comply with all specifications will invalidate the approval, and may jeopardise the fire performance.



Director of Certification
Ian Woodhouse

Date: 24 December 2019

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd

Form Number: F28 Schedule

Status: Current
Page 1 of 1

Date: 24/11/05