



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1568

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that
***Kyriakidis P. & Co. General
Partnership (Artist)***

6th km, Thessaloniki
Oraiokastro Road
Thessaloniki
Greece – 56429
Tel: +30 2310 673229

Who fabricate the following fire doors and doorsets:

Strebord EI 30 Strebord EI 60
Halspan EI 30 Halspan EI 60

have satisfied the requirements of the SDP01 Fire Resistant Timber Door scheme. This includes the testing of products to **EN1634-1** the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity & insulation** are detailed in the schedules referenced below.

Schedule refs: BMT/CNA/F13020, BMT/CNA/F13021, BMT/CNA/F14053,
BMT/CNA/F14054



First Issued: 08 July 2020
Reissued: 16 Sept 2021
Valid to: 07 July 2022
Issue No: 2

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.