



## **FIRE RESISTANT TIMBER FIRE DOORS**

***Certificate number: IFCC1570***

*Certificate only valid if verified on website [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

### ***VPK Limited***

Unit 4, Meridian Business Park  
Fleming Road  
Waltham Cross  
EN9 3BZ

Tel: 02088528800

Who fabricate the following timber fire doors and or doorsets

### **Halspan FD30, FD60, Vicaima FD30, FD60 Flamebreak FD30, FD60**

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes** integrity are detailed on page 2 of this certificate.



First Issued: 07 July 2020

Revised: 22 June 2021

Valid to: 06 July 2025

Issue No: 2

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse  
Director of Certification**



**175**

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

**Certificate number: IFCC 1570**

The production of fire resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

<b>Doorset Description</b>	<b>Fire Rating</b>	<b>Assessment/ Test Report</b>
Halspan Prima 30 min Doorsets	FD30	FEA F97174
Halspan Prima 60 min Doorsets	FD60	FEA F96103
Halspan Optima 30 min Doorsets	FD30	Chilt A01204
Halspan Optima 60 min Doorsets	FD60	FEA F01205
Halspan 30 Prima Panelled	FD30	FEA F97097
Halspan 60 Prima Panelled	FD60	Chilt A01015
Vicaima	FD30	FEA F99112
Vicaima	FD60	Chilt A13093
Flamebreak	FD30	FEA/F98164
Flamebreak	FD60	FEA/F02141

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

**It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.**

**Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.**