



# FIRE RESISTANT METAL BASED DOOR SCHEME

***Certificate number: IFCC 1628***

This is a product certificate to certify that

## **G Neophytou & Sons Ltd**

4, G Koursoumba Str Kaimakli

Nicosia

Cyprus 1028

Tel: 0035 722343408

who fabricate the following aluminium fire doorsets:

**Schüco ADS 80 FRS 30 EI30<sub>2</sub>-S<sub>a</sub>**

**&**

**Schüco ADS 80 FRS 60 EI60<sub>2</sub>-S<sub>a</sub>**

have satisfied the requirements of the SDP02 Fire resistant metal based door scheme. This includes the testing of products to **EN1634-1**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production.

The product specifications to achieve **from 30 minutes to 60 minutes** are given in the following classification reports: : 18-002402-PR02 & 18-002403-PR02



Initial certification: 3 March 2021

Revised: 23 March 2022

Valid to: 2 March 2023

Issue status: 2

Ian Woodhouse  
Director of Certification



175

IFC Certification Ltd  
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.