

IFC certification

FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1670

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

**Michalis D Pikoulis & SIA E.E
(IntraDoor)**

2nd Kilometer New Kios
Nafplio
Argos 21200 Greece
Tel: + 30 2751 051392

who fabricate timber fire doors and or doorsets:

**Intradoor Primus SF EI45
(with Metal frame)**

have satisfied the requirements of the scheme SDP01. This includes the testing of products to **EN1634-1**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and reports to achieve up to **45 minutes integrity and insulation** are detailed on page 2 of this certificate.



First Issued: 1st November 2021
Valid to: 31st October 2022
Issue No: 2

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

Page 1 of 2

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.



Certificate number: IFCC 1670

The production of fire-resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Description	Fire Rating	Assessment/ Test Report
Test report	EI45	TR-304-01
Classification report	EI45	CR-304-01

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.