



# FIRE RESISTANT TIMBER FIRE DOORS

**Certificate number: IFCC1744**

*Certificate only valid if verified on website [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

***M & J Carpentry Ltd***

SOLON MICHAELIDE No 5 AYIOS SYLAS  
Limassol  
Cyprus

Tel: 00357 25 780074

Who fabricate the following timber fire doors and or doorsets:

**Halspan EI30, Halspan EI60,**

have satisfied the requirements of the SDP01 Fire Resistant Timber Door scheme. This includes the testing of products to **EN1634-1** the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity & insulation** are detailed in the schedules referenced below.

Schedule refs: BMT/CAN/F13020, BMT/FEA/F13021



First Issued: 13 July 2022

Valid to: 12 July 2023

Issue No:1



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification

IFC Certification Ltd, Ground Floor, Suite B, Building 2, Bear Brook Office Park, Walton Street, Aylesbury HP21 7GQ  
Tel: +44(0) 1844 275500, Fax: +44(0) 1844 274002, E-mail: [uk.ifccinfo@kiwa.com](mailto:uk.ifccinfo@kiwa.com)  
Web: [www.ifccertification.com](http://www.ifccertification.com) Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd 2022