

COLT International GmbH **CERTIFICATION SCHEDULE**

for

SmokeMaster SM 5

An active smoke barrier comprising a fabric curtain (fabric reference 4415-2-SP) mounted on single or twin rollers. Single units having maximum tested width of 3004 mm and a maximum tested drop of 2985 mm. Multiple con-joined curtains with a minimum 256 mm overlap are allowed with no maximum number of units with the following limitations: Maximum tested width of individual unit 1610 mm and a maximum tested drop of 2985 mm. The curtain was evaluated in accordance with EN 12101-1: 2005+A1: 2006 and classified in accordance with EN 13501-4:2016.

Classification to EN 13501-4:2016

D – Stability duration **D₆₀₀30, D₆₀₀60, D₆₀₀90 and D₆₀₀120**
DH – Stability duration **DH30, DH60, DH90 and DH120**

Test evidence

Test Report: EFR-18-V-002119
Classification Report: EFR-18-003834



Ian Woodhouse
Director, IFC Certification

Issued 22 November 2018

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd