

## ***COLT International GmbH*** **CERTIFICATION SCHEDULE**

for

### **SmokeMaster SM 5**

An active smoke barrier comprising a fabric curtain (fabric reference 3200-2-SP) mounted on single roller. Single units having maximum tested width of 3004 mm and a maximum tested drop of 2985 mm. The curtain was evaluated in accordance with EN 12101-1: 2005+A1: 2006 and classified in accordance with EN 13501-4:2016.

---

#### **Classification to EN 13501-4:2016**

D – Stability duration      **D<sub>600</sub>30, D<sub>600</sub>60, D<sub>600</sub>90, D<sub>600</sub>120 and D<sub>600</sub>A**

---

#### **Test evidence**

Test Report: EFR-18-V-002121

Classification Report: EFR-18-V-002121



**Ian Woodhouse**  
**Director, IFC Certification**

**Issued 22 November 2018**

---

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd